

現 況 写 真

工 種	躯体工事〔構造、金物〕	撮影日 2019・ ・
確認事項	釘種、形状	実測写真

備考・説明

《左列》型式適合認定品外(現場採取)

NC50 (50mm)造作専用小径釘

頭径:4.48mm  
 胴径:2.02~2.06mm  
 長さ:49.19mm

《右列》JIS規格品

NZ45 (45mm)構造専用釘


頭径:5.8mm(±0.58)  
 胴径:2.45mm(±0.06)  
 長さ:45mm(±2.5)



頭径:4.48mm



頭径:5.57mm



胴径:2.02~2.06mm



胴径:2.45mm



長さ:49.19mm



長さ:45.14mm